



# **Energy Storage in Photovoltaic Applications**

**John Boyes, Manager  
Energy Storage and Distributed Energy Resources  
Sandia National Laboratories\***

\*Sandia is a multiprogram laboratory operated by Sandia Corporation, a Lockheed Martin Company, for the United States Department of Energy under contract DE-AC04-94AL85000





# Contents of Presentation

1. Energy Storage Technologies
2. PV Applications Requiring Storage
3. PV Battery Life Issues
4. New Application Examples





# Batteries

- **Ni-Cad**
- **Li-ion**
- **Ni-metal hydride**
- **Zn-Br flow**
- **Lead-acid**
  - **Flooded**
  - **Valve-regulated**





# **Alternate Storage Technologies**

**Pumped Hydro**

**Flywheels**

**SMES**

**Ultracaps**

**Compressed Air**

**Hydrogen**





# PV Applications Requiring Storage

## Standalone

- Remote sensing
- Remote residential
- Microgrids
- All but water pumping

## Grid-tied

- Peak shaving
- Grid stabilization
- All requiring dispatch





# Battery Impacts System Life-Cycle Cost (LCC)

- ◆ Initial Cost: \$100 to \$150/kWh
- ◆ Battery life-cycle costs for PV systems start at about 33% of the initial system cost
- ◆ Battery life-cycle costs alone can be over \$1/kWh
- ◆ Under ideal circumstances battery life-cycle costs are about \$0.35/kWh
- ◆ In many PV systems the battery is the most costly item over the life of the system





## **System Issues Reduce PV Battery Life (~ 5+ Years)**

- Overdischarge
- Incomplete Recharge
- Temperature


- Causes:**
- System Design (Array/Load)
  - Improper charging (float vs. cycling)
  - Operation (engine shut down)
  - Maintenance (clean, water, torque)



# PV-Hybrid System

## Engine-Generator Charge


- Good charge acceptance
- High power = best engine efficiency



- Poor charge acceptance
- Lots of electrolysis
- Low power = poor engine efficiency
- Necessary to fully recharge



# ACONF in Hybrid DC Power System








## What Does ACONF Do?

- ◆ **Cuts generator run time**
  - ❖ Bulk charge ends shortly after regulation voltage is reached
  - ❖ Finish charge with ACONF rather than generator
  - ❖ Utilize potentially spilled solar during finish charge periods
- ◆ **Reduce fuel use**
  - ❖ Generator runs at more efficient operating point
- ◆ **Improve battery management**
  - ❖ Finish charge to smaller termination current
  - ❖ Tight voltage and current controls applied
  - ❖ Battery performance (life) expected to improve significantly
- ◆ **Three units being successfully operated in simulated field tests (STAR, DETL)**



# Inside View of ACONF Prototype #1



Status Display

DC-DC converter

Industrial processor or PC

Solid state switches

Voltage, current sensors  
(temperature sensors)

PCB for circuit operation

Container, fans, interconnects





## **US Coast Guard NDS Remote Hybrid Power Application**

- ◆ **National Distress System (NDS) sites**
  - ❖ **Currently 24 active sites along West Coast & Alaska**
  - ❖ **Rescue 21 program will double number of sites**
- ◆ **Sites used for study**
  - ❖ **Robert Barron site: 460 watts, 19 amps**
  - ❖ **Duke Island site: 350 watts, 14.4 amps**
- ◆ **Power system consists of following**
  - ❖ **PV array providing some of annual energy requirements**
  - ❖ **Propane generator with charger: 160 amps**
  - ❖ **Absolyte IIP Battery: Two 24V strings of 1065Ah cells**
  - ❖ **Controls, limited data acquisition**




# DETL Microgrid

Secure  
SCADA Lab

Distributed  
Energy  
Resources

Loads  
(Various)

*Energy Storage in PV Applications*







# Microgrids Address Energy Surety

- Potential Microgrid Advantages
  - Diversity: fuel, resources
  - Reduce single-point vulnerabilities
  - Physical security/controls
- Military Base and Civilian Assessments Underway
- Require Standalone Operation (ENERGY STORAGE)





# **Greenpoint Manufacturing & Design Center**

**Joint Project of PowerLight and ZBB**

**Sponsored by**

**US DOE, Sandia, NYSERTA and  
Clean Air Communities**



## Greenpoint PV Project


- ◆ Choose PowerLight Solar Roof Panels to Reduce Operating Costs
- ◆ Installation of 115kW on 11,500 square feet of Unused Roof Space Was Completed in 10/2002





# Battery Energy Storage Will Be Added in Late 2003

- ◆ Solar is Used as Generated on Weekdays
- ◆ Weekend Energy Must Be Shed as Utility Will Not Allow it to be Feed back into Grid. If Storage Available, Weekend Energy Can Be Used on Monday
- ◆ Storage Can Be Used on Weekdays to Peak Shave



Solar Generation vs. Energy Use for a Typical Week at Greenpoint Facility



# Battery Energy Storage System

- ◆ Zinc Bromine Flow Battery Manufactured by ZBB and SatCon
- ◆ Two Racks Rated at 25kW/50kWh each
- ◆ Factory Testing is Complete
- ◆ Installation Planned for Late 2003







# Conclusion

- **Many PV Applications Require Storage**
- **New technologies being developed**
- **Lead-acid batteries most cost-effective**
- **Attention to system issues:**
  - **extends battery life**
  - **reduces Life Cycle Cost**





# Workshop

## **Systems Driven Approach for Solar Applications of Energy Storage**

**November 5<sup>th</sup> and 6<sup>th</sup>  
Maritime Institute, Baltimore MD**

John Boyes: (505) 845-7090, [jdboyes@sandia.gov](mailto:jdboyes@sandia.gov)

Jerry Ginn: (505) 845-9117, [jwginn@sandia.gov](mailto:jwginn@sandia.gov)